

1 2 3 4 5 6 7 8

A A

B B


C C

D D

E E

F F


1 2 3 4 5 6 7 8 A3



- ONE PIECE TOP GLAND PLATE
- SEPARATOR PLATE BETWEEN ISOLATOR/MCBs & TRANSFORMER COMPARTMENTS
- CABLE SLOTS IN SEPARATOR PLATE
- M8 FIXINGS
- SEPARATOR PLATE BETWEEN INCOMING & DISTRIBUTION SECTIONS
- ONE PIECE INSET PLATE
- 2 x 16mm² 'E' TERMINALS (B1 & B2)
- 'DZUS' LID FASTENERS
- 125A 2P INCOMING SWITCH DISCONNECTOR
- CAPTIVE SCREWS
- TRANSFORMER MOUNTING PLATE FIXINGS WELDED AT REAR
- TRANSFORMER MOUNTING PLATE FRONT FIXINGS
- BOLT ON TRANSFORMER SECTION COVER
- TRANSFORMER: PRIMARY - 220/240/260V
SECONDARY - 2 x 55V 3kVA INDEPENDENT EARTH FACILITY.
RATING - 6kVA @ 3 HOURS CONTINUOUS
4.5kVA @ 8 HOURS CONTINUOUS
CLASS 'F' CONSTRUCTION.
- PRIMARY TERMINAL BLOCK



CUSTOMER INFORMATION COPY



UNUSED HOLES TO BE BLANKED OFF WITH FIXINGS AND SEALED

NOTES.
 FINISH: BLACK, LUL APPROVED.
 MATERIALS: LOW FIRE HAZARD WHERE POSSIBLE.
 ENCLOSURE: IP55.
 DESIGNATION/WARNING LABELS NOT SHOWN FOR CLARITY.

REV:	A	B	C	D	E	F	G	H	I	J		
EDR:	2698	4067	4701	4790	4825	4885	5841	5868	6338	6785		
UNLESS OTHERWISE STATED:- ALL DIMENSIONS IN MM. TOLERANCES TO H30052 FIXING STANDARD TO H30051 WIRING STANDARD TO H20051 WELDING STANDARD TO QAI 61.						MATERIAL		-		SIZE		-
DO NOT SCALE THIS DRAWING. IF IN DOUBT, ASK						REF. 93/SQ.1743		COPY ISSUED				
TITLE						ORIGINAL SCALE 1:5		DATE. 02.03.16		BLAKLEY ELECTRICS LIMITED		
GENERAL ASSY TRANS./DIST BOARD L.U.L.						DRN. B.JONES		CHKD.				
						APPD.		SHEET 1 OF 1				

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF BLAKLEY ELECTRICS AND MUST NOT WITHOUT THEIR WRITTEN CONSENT BE PASSED ON, COPIED, OR USED FOR ANY OTHER PURPOSE. THIS COPY IS UNCONTROLLED UNLESS OTHERWISE MARKED.